

Corrigendum – III**Pre-Bid Clarifications****Tender Notice no. NREDCAP/GCRT/RESCO-1/2025-26 Dated. 20.02.2026**

Name of the work: Request for Selection (RfS) of Solar Power Developer for implementation of 826 kW Grid Connected Rooftop Solar Plants for Government Schools and Hostels under RESCO Mode in Chittoor District of Andhra Pradesh

Sl.	Query	Reply
1	Payment Security Mechanism: Kindly clarify the payment security mechanism decided by the client organisation for the project to ensure timely payments to the developer.	Tender conditions prevail. Please refer to clauses 7.4, 7.5, and 7.6 of PPA for invoice, and payments. Client Organisation shall ensure the timely payments. Further, Late Payment Surcharge is applicable in case of any delay in payments as per clause 7.7 of PPA.
2	Structural Feasibility of Buildings: During detailed site assessment, if certain buildings are found to have structural limitations or safety concerns for rooftop solar installation, kindly confirm whether such buildings can be excluded from the scope of the project.	Tender conditions prevail. As per clause 1.2 of RfS and point no. I.2 of Corrigendum II, Prospective Bidders will be required to assess the feasibility of roof space of the identified buildings. However, Client Organization reserves the decision on the final determined capacity. Further in case of any structural limitations or safety concerns, efforts shall be made to find alternative site within the school/hostel campus. In absence of such alternatives, such buildings shall be excluded from the scope.
3	Module Specifications: Kindly clarify the specifications of solar PV modules to be used in the project, including whether the modules are required to be DCR or Non-DCR, or any specific technical requirements.	Tender conditions prevail. As per clause 1.5.4. of RfS, the solar PV modules and solar PV cells used in the Projects under this RfS shall be from the models and manufacturers included in ALMM List-I (for solar PV modules) and ALMM List-II (for solar PV cells).
4	AC-DC Ratio: As per the tender document, it is mentioned that 100% AC capacity shall be equal to 100% DC capacity. We request clarification on whether flexibility in the AC-DC ratio (DC overloading) will be permitted, as allowing a higher DC capacity compared	Tender conditions prevail, please refer to clause 9 in Annexure C of RFS.

Sl.	Query	Reply
	to AC capacity helps optimize plant performance and generation.	
5	<p>Site Details:</p> <p>Kindly provide the complete list of project sites along with geo-coordinates (latitude & longitude) to enable proper site assessment and generation estimation.</p>	<p>The complete list of project sites along with geo-coordinates are provided at Annexure-1 in this document.</p>
6	<p>Delay in DISCOM Approvals:</p> <p>In case there is a delay in obtaining approvals such as net-metering / interconnection approvals from the DISCOM, which may consequently delay the project COD, kindly clarify whether such delays will be considered permissible and excluded from any penalties applicable to the developer.</p>	<p>As per RFS clause 7.8.(b), Obtaining No Objection Certificate (NOC) and all necessary approvals from DISCOM for grid connectivity and Net Metering is the responsibility of Solar Power Developer. All charges related to net metering shall be borne by the Solar Developer.</p> <p>In case of delays not attributable to Solar Power Developer, Solar Power Developer needs to get prior approval from NREDCAP, at least 10 days before Scheduled Commissioning Date (SCD), stating the reasons to ensure necessary facilitation by NREDCAP.</p>
7	<p>Building Closure/Load Reduction:</p> <p>In the event that any school, hostel, or building becomes non-operational or experiences significant reduction in electricity consumption during the project tenure, kindly clarify the mechanism available to safeguard the developer's investment, such as allocation of alternate buildings or other suitable provisions.</p>	<p>Please refer to clause 5.3 of PPA and Point I.1 of Corrigendum II.</p>
8	<p>Early Termination Clause:</p> <p>Kindly clarify the provisions related to early termination of the agreement. In case the contract is terminated before completion of the project tenure due to reasons not attributable to the developer, kindly specify the compensation mechanism to safeguard the developer's investment.</p>	<p>Please refer to clause 12.2 (b) of PPA</p>
9	<p>Payment Timeline:</p> <p>Kindly clarify the payment timeline's from the client organization for energy bills/invoices raised by the developer. Additionally, please specify the provisions in case of delayed payments,</p>	<ul style="list-style-type: none"> • Purchaser shall pay all amounts due hereunder within 45 days after the date of the receipt of the invoice at Purchaser's office as per clause 7.5 of PPA. • Late Payment Surcharge shall be as per clause 7.7 of PPA.

Sl.	Query	Reply
	including whether any late payment surcharge (LPS) or interest on delayed payments will be applicable.	
10	NREDCAP Facilitation Fee: As per the tender conditions, a facilitation fee of ₹0.10 per unit is payable to NREDCAP. Kindly clarify the timeline within which this amount is to be credited after receipt of payment from the client organization, and the mechanism for depositing the same.	The Solar Power Developer shall pay the service charges to NREDCAP as per tender conditions within 1 week of receipt of payment from client organization. Refer to point I.3 of Corrigendum II

Sd/-

VC & Managing Director

NREDCAP

Annexure – 1

Sl. No.	Name of the Department	Name of the Hostel / Residential School	Name of the Grama Sachivalayam	Mandal	Electricity Service Numbers	Yearly consumption of electricity (in units)	Available Shadow free area (in Sq. Mtrs)	Proposed Solar system size (in KW)	Latitude	Longitude
1	Tribal Welfare	GTW Ashram Girls School, Vijalapuram, Vijalapuram (V), Ramakuppam (M), Chittoor District, A.P - 517401	Vijalapuram	Ramakuppam	33500904	3,600	135	5	12.837872	78.457026
2	Tribal Welfare	APTWRS (B), Bangarupalem, Thagguvaripalli (V), Bangarupalem (M), Palamaner Road, Chittoor Dist, A.P- 517416	Thagguvaripalli	Bangarupalem	511410000 1433 School	7,007	144	5	13.196738	78.914808
					511410000 1434 Hostel	7,110	52	5	12.908612	78.472786
3	Tribal Welfare	APTWRS (B) Ramakuppam, Thimmasamudram colony(V) Ramakuppam(M), Chittoor Dist,A.P - 517401	Thimmasamudram	Ramakuppam	31800272	15,226	162	10	13.218943	79.121831
4	Tribal Welfare	APTWRS (G) Chittoor Sanjay Gandhi Nagar, Near Govt. I.T.I., Estate, Chittoor Dist, A.P- 517001	Sanjay Gandhi Nagar	Chittoor	511240201 1543 School Service	15,773	108	10	13.218083	79.121343

Sl. No.	Name of the Department	Name of the Hostel / Residential School	Name of the Grama Sachivalayam	Mandal	Electricity Service Numbers	Yearly consumption of electricity (in units)	Available Shadow free area (in Sq. Mtrs)	Proposed Solar system size (in KW)	Latitude	Longitude
5	Tribal Welfare	GTWCH (B) Chittoor, Beside APTWRS(G), Sanjay Gandhi Nagar, Near Govt. I.T.I., Estate, Chittoor Dist, A.P.- 517001	Sanjay Gandhi Nagar	Chittoor	511240200 7447	770	48	3	12.90712	78.47159
6	APSWREIS	Dr. B.R.Ambedkar Gurukulam (B), Ramakuppam	Ramakuppam	Ramakuppam	591231000 0132 School Service	31,098	135	10	12.90712	78.47159
					591231000 0130 Kitchen & Old Dormitory	11,960	310	10		
					591231000 0371 New Dormitory	7,110	108	5		

Sl. No.	Name of the Department	Name of the Hostel / Residential School	Name of the Grama Sachivalayam	Mandal	Electricity Service Numbers	Yearly consumption of electricity (in units)	Available Shadow free area (in Sq. Mtrs)	Proposed Solar system size (in KW)	Latitude	Longitude
7	APSWREIS	Dr. B.R.Ambedkar Gurukulam (G), Chittoor	Sanjay Gandhi Nagar	Ramakuppam	511240200 9158	88,556	252 School Building	50	13.217162	79.122406
							108 Dormitory			
							261 New Mess			
8	APSWREIS	Dr. B.R.Ambedkar Gurukulam (G), Palamaner	Palamaner (Old Peta)	Palamaner	582140100 0725	64,425	501 School Building	45	13.203177	78.727136
9	APSWREIS	Dr. B.R.Ambedkar Gurukulam (G), Kuppam	Cheelepalli	Kuppam	591122500 0198	1,37,319	184 School Building	20	12.7409	78.3442

Sl. No.	Name of the Department	Name of the Hostel / Residential School	Name of the Grama Sachivalayam	Mandal	Electricity Service Numbers	Yearly consumption of electricity (in units)	Available Shadow free area (in Sq. Mtrs)	Proposed Solar system size (in KW)	Latitude	Longitude
10	APSWREIS	Dr. B.R.Ambedkar Gurukulam (G), G.D.Nellore	Vepanjeri	Gd Nellore	561210600 2683	98,000	198 School Building	35	13.225002	79.219205
							168 Dining Hall			
11	APSWREIS	Dr. B.R.Ambedkar Gurukulam (B), Puthalapattu	Chittipiralla	Puthalapattu	511140600 0403	1,02,372	120 Hostel Building	40	13.416556	79.120444
							320 Dining Hall			
12	APSWREIS	Dr. B.R.Ambedkar Gurukulam (B), Vijalapuram	Kadapalli	Santhipuram	591241200 0701	94,432	480	50	12.816222	78.374127

Sl. No.	Name of the Department	Name of the Hostel / Residential School	Name of the Grama Sachivalayam	Mandal	Electricity Service Numbers	Yearly consumption of electricity (in units)	Available Shadow free area (in Sq. Mtrs)	Proposed Solar system size (in KW)	Latitude	Longitude
13	BC Welfare	Govt. B.C. Boys Hostel, Chittoor, Sanjay Gandhi Nagar, Near Employment Office, Industrial Estate, Chittoor - 517002.	Ward 6	Chittoor	511240201 1049	22,395	146	15	13.2178	79.121549
14	BC Welfare	Govt. B.C. Girls Hostel, Penumur, Puttur Road, Penumur,- Pin.No.517002	Bazar Street Ward	Penumur	511150080 4124	5,225	700	5	13.37253	79.19721
15	BC Welfare	Govt. B.C. Boys Hostel, Kallur, Punganur Road, Near Z.P. High School, Kallur	Kallur 1	Pulicherla	583110000 2083	12,457	200	10	13.55688	78.99281
16	BC Welfare	Govt. B.C. Boys Hostel, Rompicherla Besides M.R.O Office, Rompicherla	Bommaiahgaripalli	Rompicherla	583120000 4054	13,270	130	10	13.67112	79.0406
17	BC Welfare	Govt.B.C.College Girls Hostel, Chittoor, Valliyappa Nagar, Near Krishaveni College, Chittoor. Pin-517002	Prashanth Nagar(15Th Ward Sachivalayam)	Chittoor	511230200 3083	27,129	84	10	13.19052	79.0968

Sl. No.	Name of the Department	Name of the Hostel / Residential School	Name of the Grama Sachivalayam	Mandal	Electricity Service Numbers	Yearly consumption of electricity (in units)	Available Shadow free area (in Sq. Mtrs)	Proposed Solar system size (in KW)	Latitude	Longitude
18	BC Welfare	Govt. B.C. Boys Hostel, Baireddypalle Near Indian Bank, Kupam Raod, Baireddypalle - Pin-517415	Baireddypalli-1	Baireddipalle	582110000 1793	4,750	180	5	13.09192	78.615422
19	BC Welfare	Govt. B.C. Boys Hostel, Gudupalle Door.No.106, Gudupalle - Pin 517426	Gudupalle	Gudupalle	591170300 2436	3,864	216	3	12.79197	78.27793
20	BC Welfare	Govt. B.C. Boys Hostel, Palamaner Gudiyatham Road, Palamaner, Pin-517408	Ts Agrapharam	Palamaner	582130400 2154	12,000	100	10	13.19255	78.745545
21	BC Welfare	Govt. B.C. Girls Hostel, V.Kota Door.No.3-35, V.Kota Pin-517524	V. Kota 1	V.Kota	582150000 3632	17,438	165	10	13.00021	78.48779
22	BC Welfare	Govt.B.C.College Girls Hostel, Kuppam J.P. Road, Near M.S.C. Govt. Junior College, Kuppam - 517425.	Kuppam 5	Kuppam	591110200 04203	19,008	110	12	12.74569	78.338529
23	BC Welfare	Govt.B.C.College Boys Hostel, Kuppam D.No.1-461, NTR Colony, Newpet, Kuppam	Chillepalli	Kuppam	591110204 290	12,930	105	10	12.74849	78.34558

Sl. No.	Name of the Department	Name of the Hostel / Residential School	Name of the Grama Sachivalayam	Mandal	Electricity Service Numbers	Yearly consumption of electricity (in units)	Available Shadow free area (in Sq. Mtrs)	Proposed Solar system size (in KW)	Latitude	Longitude
24	BC Welfare	Govt. B.C. Boys Hostel, Katherapalli Behind Z.P. High School, Main Road, Katherapalli	Katherapalli	Kareveti Nagar	5343313000820	9,972	240	5	13.36654	79.38867
25	BC Welfare	Govt. B.C. Boys Hostel, Zambada Opp Govt.High School, Zambada	Kosalanagaram	Vijayapuram	5621317000579	3,036	135.3	3	13.23736	79.71447
26	BC Welfare	Govt. B.C. Boys Hostel, Pachikapallam Near ZP High School, Penumuru Road, Pachikapallam	Pachikapallam	Vedurukuppam	5634226002458	3,132	72	3	13.24371	79.233813
27	BC Welfare	Govt. B.C. Girls Hostel, Palasamudram Near Police Station, Palasamudram - Pin 517599	Palasamudram	Palasamudram	5612310001121	4,296	139.35	3	13.21042	79.386314
28	BC Welfare	Govt. B.C. Boys Hostel, V.R.Kuppam Vengalaraju Kuppam, Pin-517599	V.R.Kuppam	Palasamudram	5612315000277	4,608	1011	3	13.20655	79.373209
29	BC Welfare	Govt.B.C.College Boys Hostel, Nagari D.No.1-106, Ramulagoudi st, Karakantapuram, Nagari, Pin.517592	Karakantapuram	Nagari	5621424000363	20,640	195	15	13.31983	79.56246

Sl. No.	Name of the Department	Name of the Hostel / Residential School	Name of the Grama Sachivalayam	Mandal	Electricity Service Numbers	Yearly consumption of electricity (in units)	Available Shadow free area (in Sq. Mtrs)	Proposed Solar system size (in KW)	Latitude	Longitude
30	SC Welfare	Govt [Sw] Boys Hostel No.2 - Chittoor, Near Residentialschool, Sanjaya Nagar,Chittoor	S N Puram, Sanjay Gandhi Nagar	Chittoor	511240200 7454	3,148	80	5	13.217713	79.122286
31	SC Welfare	Govt [Sw] Girls Hostel - Gudipala, Beside Z P High School, Gudipala	Vasanthapuram	Gudipala	511330600 1092	2,495	36	3	13.099615	79.12394
32	SC Welfare	Govt [Sw] Girls Hostel No.1 - Chittoor, Lakhmi Nagar Colony, Chittoor	Venkateswara Colony	Chittoor	511240200 7453 Hostel	8,642	324	10	13.210251	79.110538
33	SC Welfare	Govt [Sw] College Girls Hostel No.3 - Chittoor, Lakhmi Nagar Colony, Chittoor	Venkateswara Colony	Chittoor	511240200 0710 Kitchen & Dining	3,990	24	3	13.210252	79.110538
34	SC Welfare	Govt [Sw] College Boys Hostel No.2 - Chittoor, Beside Dmho Office, Vellore Road, Chittoor	Prasanth Nagar	Chittoor	511230200 3810	25,106	310	15	13.186177	79.095281
35	SC Welfare	Govt [Sw] College Girls Hostelno.2 -Chittoor, Beside B C Bhavan,Vellore Road,Chittoor	Prasanth Nagar	Chittoor	511230200 3869	17,155	264	15	13.192043	79.095283

Sl. No.	Name of the Department	Name of the Hostel / Residential School	Name of the Grama Sachivalayam	Mandal	Electricity Service Numbers	Yearly consumption of electricity (in units)	Available Shadow free area (in Sq. Mtrs)	Proposed Solar system size (in KW)	Latitude	Longitude
36	SC Welfare	Govt [Sw] Boys Hostel - G.D.Nellore, Opposite To Hp Patrol Bunk, Puthur Main Road	G D Nellore	Gd Nellore	561220700 0592	4,113	500	5	13.238279	79.185916
37	SC Welfare	Govt [Sw] Boys Hostel - Kothapalli Mitta, Opposite To Zphs, Kothapalle Mitta , Puthur Main Road , S R Puram	Kothapallimitta	Sr Puram	563410300 0701	3,600	1500	3	13.291189	79.254039
38	SC Welfare	Govt [Sw] Boys Hostel - Penumur, Opp- Indian Oil Petrol Bunk,Nendragunta Road , Penumuru	Penumur	Penumur	561240000 1057	3,624	500	3	13.368306	79.19372
39	SC Welfare	Govt [Sw] Boys Hostel - Thungundram, Baliya Kandriga Road, Thungundram, G D Nellore	Thugundram	Gd Nellore	561210200 0619	4,670	130	3	13.191748	79.269204
40	SC Welfare	Govt [Sw] Boys Hostel - Ugranampalle, Beside Z.P.High School, Penumur Road, Ugranampalli, Penumuru Mandal	Ugranampalli	Penumur	561240300 0206	2,984	65	3	13.322662	79.186984
41	SC Welfare	Govt [Sw] Girls Hostel - Gangadhara Nellore, Library Street , G D Nellore	G D Nellore	Gd Nellore	561220700 0354	3,013	97.54	3	13.231922	79.181298

Sl. No.	Name of the Department	Name of the Hostel / Residential School	Name of the Grama Sachivalayam	Mandal	Electricity Service Numbers	Yearly consumption of electricity (in units)	Available Shadow free area (in Sq. Mtrs)	Proposed Solar system size (in KW)	Latitude	Longitude
42	SC Welfare	Govt [Sw] Girls Hostel Iwhc - Karvetinagar, Near R & B Guest House, Puttur Road, Karvetinagaram	Karvetingar 2	Kareveti Nagar	563430000 2203	13,154	242	10	13.4302	79.454848
43	SC Welfare	Govt [Sw] Boys Hostel - Devalampeta, Near Z.P.H.S Backside, Jadapanapalli Road, Bommepalli, Devalampeta, Vedhukuruppam	Devalampeta	Vedurukuppam	563420900 0407	1,110	130	3	13.323501	79.238947
44	SC Welfare	Govt [Sw] Boys Hostel - Pachikapallam, Near Govt High School Back Side, Pachiakapalm, Vedhukuruppam	Pachikapallam	Vedurukuppam	563422600 1384	5,076	1500	5	13.443833	79.35892
45	SC Welfare	Govt [Sw] Boys Hostel No.2 - Karvetinagar, Near Govt Degree College, Puttur Road, Karvetinagaram	Karvetingar 2	Kareveti Nagar	563430800 0757	1,200	84	5	13.429617	79.465994
46	SC Welfare	Govt [Sw] Girls Hostel - Vedurukuppam, Near To Z.P.H School Ground, Chavatagunta, Vedhukuruppam	Vedurukuppam	Vedurukuppam	563420700 0509	4,500	150	3	13.440556	79.315000

Sl. No.	Name of the Department	Name of the Hostel / Residential School	Name of the Grama Sachivalayam	Mandal	Electricity Service Numbers	Yearly consumption of electricity (in units)	Available Shadow free area (in Sq. Mtrs)	Proposed Solar system size (in KW)	Latitude	Longitude
47	SC Welfare	Govt [Sw] College Boys Hostel, K.Nagar, Near Subramanyam Swami Temple, Karvetinagaram	Karvetinagar 1	Kareveti Nagar	563430000 1664	3,156	48	5	13.415983	79.452273
48	SC Welfare	Govt [Sw] Boys Hostel - Dandikuppam, Beside Z.P.High School, Dandikuppam, Santhipuram	Dandikuppam	Santhipuram	591240700 0120	4,500	50	3	12.872071	78.438069
49	SC Welfare	Govt [Sw] Boys Hostel - Kuppam, Muniswaminipuram Sc Colony , Oldpet Kuppam, Kuppam	Kuppam 1	Kuppam	591110300 0344	2,500	80	3	12.751472	78.348116
50	SC Welfare	Govt [Sw] Girls Hostel - Rallabudugur, Near Kgf Road, Rallabuduguru, Santhipuram	Rallabuduguru	Santhipuram	591242200 0799	3,000	108	5	12.858923	78.343652
51	SC Welfare	Govt [Sw] College Girls Hostel - Kuppam, Near Muthu Marriamma Temple, Ramachendra Road, Kuppam	Kuppam 3	Kuppam	581110400 1457	14,000	45	5	12.749379	78.34291
52	SC Welfare	Govt [Sw] College Boys Hostel - Kuppam, Rkm Nagar Street, Sreelanka Colony, D K Palli Panchayath, Kuppam	D K Pallai 1	Kuppam	591110600 0714	30,589	310	30	12.74748	78.324206

Sl. No.	Name of the Department	Name of the Hostel / Residential School	Name of the Grama Sachivalayam	Mandal	Electricity Service Numbers	Yearly consumption of electricity (in units)	Available Shadow free area (in Sq. Mtrs)	Proposed Solar system size (in KW)	Latitude	Longitude
53	SC Welfare	Govt [Sw] Boys Hostel - Baireddipalle, Near Punganur Road, Zphs Baireddipalli	Baireddipalli 1	Baireddipalle	582110000 0582	6,722	81	6	13.091051	78.608279
54	SC Welfare	Govt [Sw] Boys Hostel - V.Kota, Inside Of Z.P.High School Compound, V.Kota	Ambedkar Nagar	Venkatagirikota	582150000 4740	9,598	92	8	13.001718	78.490528
55	SC Welfare	Govt [Sw] Boys Hostel - Kolamasanapalle, Palamaner - Krishnagiri Highway, Kolamasnapalli, Palamaner Rural	Kolamasanapalli	Palamaner	582140300 1966	9,705	120	8	13.152524	78.677474
56	SC Welfare	Govt [Sw] Boys Hostel No.1 - Palamaner, Gudiyatam Road, Opp:Svcr Degree College, Palamaner Urban	Ts Agraharam	Palamaner	582130400 0772 Hostel Building	6,000	1000	5	13.191631	78.744008
					582130400 0771 Kitchen & Dining	996	200	3		
57	SC Welfare	Govt [Sw] Boys Hostel No.2 - Palamaner, Gudiyatam Road, Opp:Svcr Degree College, Palamaner Urban	T S Agraharam	Palamaner	582130400 5281	4,555	198	5	13.191427	78.743774

Sl. No.	Name of the Department	Name of the Hostel / Residential School	Name of the Grama Sachivalayam	Mandal	Electricity Service Numbers	Yearly consumption of electricity (in units)	Available Shadow free area (in Sq. Mtrs)	Proposed Solar system size (in KW)	Latitude	Longitude
58	SC Welfare	Govt [Sw] Girls Hostel - Palamaner, Gobbilakotur, Near O.L.L.U.P.School, Palamaner Urban	T S Agraharam	Palamaner	582130400 1540	7,481	264	6	13.200426	78.753297
59	SC Welfare	Govt [Sw] Girls Hostel - Rayalpet, Solimpalle, Rayalpeta, Peddapanjani	Rayalpeta	Peddapanjani	581121200 1698	3,500	120	5	13.334248	78.727018
60	SC Welfare	Govt [Sw] Boys Hostel - Irala, Beside Z P High School, Irala	Irala	Irala	512140000 2750	3,507	650	5	13.395065	78.983728
61	SC Welfare	Govt [Sw] Girls Hostel - Irala, Near P H C, Irala	Irala	Irala	512140000 0941	5,492	720	5	13.384163	78.987678
62	SC Welfare	Govt [Sw] Boys Hostel - P.Kothakota, Near Ramalayam, P. Kothakota, Puthalapattu	P Kothakota	Puthalpattu	511141200 0752	2,398	120	5	13.406406	79.10948
63	SC Welfare	Govt [Sw] Boys Hostel - Puthalapattu, Adjacent To Zphs, Puthalapattu	Puthapattu 1	Puthalpattu	511340000 0766	4,443	260	5	13.347686	79.092683

Sl. No.	Name of the Department	Name of the Hostel / Residential School	Name of the Grama Sachivalayam	Mandal	Electricity Service Numbers	Yearly consumption of electricity (in units)	Available Shadow free area (in Sq. Mtrs)	Proposed Solar system size (in KW)	Latitude	Longitude
64	SC Welfare	Govt [Sw] Boys Iwhc - Bangarupalem, Aragonda Road, Near Bsnl Office, Thagguvaripalli, Bangarupalem	Tagguvaripalle	Bangarupalem	5114100004708	4,555	118	5	13.202744	78.913816
65	SC Welfare	Govt [Sw] Girls Hostel - Yadamari, Paradarami Road, Yadhamari	Yadamari	Yadamari	5114317002402	8803	600	6	13.16097	79.038828
66	SC Welfare	Govt [Sw] Girls Hostel No.1 - Bangarupalem, Kurappalli, Near Mppschoo, Bangarupalem	Tagguvaripalle	Bangarupalem	5114100001970	5,698	72	5	13.197967	78.916992
67	Education	A.P. Model School, Rompicherla	Bommaiahgaripalle	Rompicherla	5831204005109	19,093	206	20	13.6505723	79.0358217
68	Education	A.P.Model School, Baireddipalle	Kammanapalli	Baireddypalli	5821118000773	27,000	30	3	13.120002	78.63049
69	Education	A.P.Model School, Gudupalli	Gudupalle	Gudupalle	5911701000686	13,636	200	10	12.78903	78.2939

Sl. No.	Name of the Department	Name of the Hostel / Residential School	Name of the Grama Sachivalayam	Mandal	Electricity Service Numbers	Yearly consumption of electricity (in units)	Available Shadow free area (in Sq. Mtrs)	Proposed Solar system size (in KW)	Latitude	Longitude
70	Education	A.P.Model School, Nadimur	Nadimuru	Kuppam	20400651 (591121100 0651)	9,381	80	8	12.68106	78.33875
71	Education	APRS (G), Kammanapalle	Kammanapalli	Baireddypalli	582111800 0081	27,196	200	20	13.1170068	78.6296765
72	SSA	KGBV, Baireddipalle	Kammanapalli	Baireddypalli	582111800 0652	33,600	225 Hostel Building 324 New College Building	20	13.12084	78.630558
73	SSA	KGBV, Gangavaram	Gangavaram I	Gangavaram	582120000 3306	25,296	100	10	13.224575	78.749613

Sl. No.	Name of the Department	Name of the Hostel / Residential School	Name of the Grama Sachivalayam	Mandal	Electricity Service Numbers	Yearly consumption of electricity (in units)	Available Shadow free area (in Sq. Mtrs)	Proposed Solar system size (in KW)	Latitude	Longitude
74	SSA	KGBV, Gudupalle	Gudupalle	Gudupalle	591170100 0490	14,422	324	15	12.803334	78.297515
75	SSA	KGBV, Kanamaladoddi	Morasanapalle	Santhipuram	591241200 0503	13,628	300	5	12.81799	78.372103
76	SSA	KGBV, Paramasamudram	Cheelepalli	Kuppam	591122500 0257	4,500	346	5	12.723758	78.313167
77	SSA	KGBV, Ramakuppam	Vijilapuram	Ramakuppam	33501317 (591232100 1317)	30,500	216 School Building	30	12.839932	78.455415

Sl. No.	Name of the Department	Name of the Hostel / Residential School	Name of the Grama Sachivalayam	Mandal	Electricity Service Numbers	Yearly consumption of electricity (in units)	Available Shadow free area (in Sq. Mtrs)	Proposed Solar system size (in KW)	Latitude	Longitude
							90 Intermedial College			
78	SSA	KGBV, Rompicherla	Motumallela	Rompicherla	583120000 4742	19,272	575.5	15	13.671245	79.046424
						13,67,210 Units		826 kW		