

Request for Selection (RFS) of Bidders for implementation of Grid Connected Solar Roof Top PV Systems for Government Buildings in Andhra Pradesh under RESCO Model – Clarifications on queries of M/s Azure Power vide mail dated 03.07.2018

S.No	Part/Page No.	Clause	Specification	Clarification Required	Amendment made, if any
1	Section III/ Page 41	23-Data Acquisition system/Plant Monitoring-II	Data Logging Provision for plant control and monitoring, time and date stamped system data logs for analysis with the high quality, suitable PC. Metering and Instrumentation for display of systems parameters and status indication to be provided.	Online monitoring shall be provided for data acquisition & logging for each plant. Thus a separate PC will not be required.	Not agreed
2	Section III/ Page 42	Cables	For the AC cabling, PVC or, XLPE insulated and PVC sheathed single or, multi-core multistranded flexible copper cables shall be used; Outdoor AC cables shall have a UV- stabilized outer sheath	Kindly allow AC cable as Aluminum on AC side, which is common in practice and also cable theft issue can also be minimised.	Agreed

VC & Managing Director