

## SCOPE OF WORK OF EMPANELLED SUPPLIER

- a. **Scope of work covers Design, Supply, Installation & Commissioning of SPV Rooftop as per the technical specification.**
- b. **The cost is inclusive of all taxes, duties, packing, forwarding and transportation costs upto the site.**
- c. **The processing charges payable to APDISCOMs(Rs.1000) and NREDCAP (Rs.1000 (1-3 KWp) or Rs.5000 (5 KWp) + Service Tax@12.36%) and also cost of Bi-directional meter shall be borne by the beneficiary.**
- d. **Wiring upto Distribution Board from the SPV Rooftop system will be in the scope of the Supplier. The maximum cable length of 25m for every Solar power plant installed shall be in the scope of the supplier and supply of excess cable length if required shall be in the scope of purchaser.**
- e. **Mounting Structure within the scope of the supplier for flat RCC roofs. If the roof is not flat and requires additional mounting structure then that cost will have to be separately borne by the applicant.**
- f. Performance testing of the complete system.
- g. The Supplier shall supply spares free of cost for the maintenance of the offered items during the warranty period.
- h. A leaflet containing the details of the service centres shall be provided to each purchaser.
- i. If the operation or use of the system proves to be unsatisfactory during the warranty period, the supplier shall replace the faulty ones or carry out necessary repairs as per the warranty terms and conditions.
- j. The Comprehensive Maintenance Charges (CMC) from 6<sup>th</sup> to 10<sup>th</sup> year to be paid to the Supplier is optional.
- k. The eligible MNRE and State subsidy will be released based on MNRE/State Govt. Policies and guidelines either directly to the supplier or to the beneficiary, based on the declaration submitted by the beneficiary.
- l. The procedure for availing subsidy and for submission of proposals shall be as per details uploaded in the web-site: [www.nedcap.gov.in](http://www.nedcap.gov.in).
- m. The proposals for installation of the system shall be made before installation of actual system.